




CSI COLLEGE OF ENGINEERING, KETTI
Approved by AICTE, New Delhi (F.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



ELECTRICAL WORK COMPLAINING REGISTER



R. Mury Shantri
PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 215.



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001



DATE	NAME	Room	REPORT	Sl. No.	Work Done	STAFF	REMARKS
19/8/23	Mutha/Gnesh	14	Tubelight not working	1	1' TL light (110) TL starter (110) OK	W	
24/8/23	Sanjay	13	Tubelight; halogen bar	2	4' LED (110) replaced bulb OK	W	
24/8/23	Jayashree	15	switchgear damaged tubelight not working	3	TL starter (110) changed OK 5A socket changed	W	
24/8/23	Sanjay	12	Tubelight Not working	4	checked working fine connecting	W	
24/8/23	S.Thanish Selvan	04	Tubelight not working window glass broken	5	TL starter (110) changed OK	W	
25.01.2023							
25/01/23	P. Radhakan	33	Tubelight Not working	6	checked OK	W	
30/8/23	VARUN.M	12	Tubelight not working change to LED light.	7	checked OK, changed to LED	W	
30/8/23	Ajay S	58	Water Duct, shaking issue	8	Cross fields, pipes to be done	W	
28/09/23	S.Suganarub	15	Tubelight, window glass broken	9	1' TL light (110) TL starter (110) changed OK	W	
21/8/23	R.No.62		one new LED fitting Replaced	10		W	
1/8/23	R.No.63		one new LED fitting Replaced	11		W	
1/8/23	R.No.64		one new LED fitting Replaced	12		W	
1/8/23	R.No.65		one 5A socket changed	13		W	
8/12/23	K.Ganeshan	R.no:62	Tubelight not working change to LED light	14		W	



R. Mary Shanmughi
PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI-643 216.



Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



S.no	DATE	NAME	Room no	REPORT	S.no
			23	Tube light Problem	
	3-1-23	N. Aadarsh Paul	27	Tube light Problem	
	2	Jack D	28	Tube light Problem	
	3	John Jack	36	one tube and socket Problem	
	4	Alum	14	tube light problem 2 light	
	4	EBINESH			
	28/1/23	Prigamank	14	Tube light Problem solved	
	31/1/2023	Praveen Bala	47	Checked ok 2 tubes	
		Assistant warden	48	Electrical problem of Lock problem	
	4/02/23	R. NO - Akil M B	49	Electrical Problem	
		Saran. M	13	two tube lights and the window broken	
	7/02/21	Talithankar	12	window Glass, tube light	
		U. Agrawalhakumar	05	Tube light Problem	
	13/2/23	Water docket problem		attended and rectified	
	13/2/23	Water docket repair		checked and rectified	
	14/2/23	R. NO - 6 -		one tube light and switch	
				11/4/23 Charged	
	14/2/23	R. NO 32.		one tube light and two switches	
				Charged	
	4/2/23	R. NO - 51 -		one tube light changed	
	4/2/23	R. NO - 6 -		One tube light changed	

R. Mary Shanthi

PRINCIPAL
C.S.I. COLLEGE OF ENGINEERING,
KETTI - 643 216.






CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23.3.1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31.12.2001)



ELECTRICAL MAINTANENCE RECORD



R. Mary Shanmugam
PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 216.



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23.3.1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f. 31.12.2001)



5					
Date	Purpose & rt-Complian	Completed	Incompleted	Sign Electrical	May man
3.11.23	Fly killer Not working		"		
16.11.23	Weathering Not working	OK 5/12/23			
5.12.23	No Compliance				
6.12.23	"	Nil	Nil		
7.12.23	"	Nil	Nil		
8.12.23	"	"	"		
9.12.23	"	"	"		
10.12.23	"	"	"		
11.12.23	"	"	"		
12.12.23	"	"	"		
13.12.23	"	"	"		
14.12.23	"	"	"		
15.12.23	No Compliance	Nil	Nil		
16.12.23	D. Hall W.D. Not working				
17.12.23	"	Completed	Nil		
18.12.23	"	"	"		
19.12.23	"	"	"		
20.12.23	Mass Star work	"	"		
21.12.23	"	"	"		
22.12.23	to 02/1/24	Holiday			
3.1.24	"	"	"		
4.1.24	Fly killer Not working				
5.1.24	"	Completed			
6.1.24	"	No Comp			
8.1.24	Boys Hostel W.D. Not Working				
10.1.24	"	Completed			
12.1.24	"	"	"		
18.1.24	"	"	"		
19.1.24	"	"	"		
21.1.24	"	"	"		
22.1.24	No Compliance				
23.1.24	"	"	"		
24.1.24	"	"	"		



R. M. S. Senthil
PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI-643 216,

**CSI COLLEGE OF ENGINEERING, KETTI**

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23.3.1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f. 12 2001)



Date	Purpose of Complaint	Completed	Incomplete	Em.	M.M.
30.6.24	Cable Work	Not Completed			By
2.7.24	"	"			By
4.7.24	"	"			By
6.7.24	"	"	Incomplete		By
9.7.24	Pest o Flash	Not working			By
11.7.24	Pest o Flash	Not working			By
13.7.24	Pest o Flash	Not working			By
15.7.24	Pest o Flash	Not working			By
17.7.24	Pest o Flash	Not working			By
19.7.24	Pest o Flash	Not working			By
21.7.24	Pest o Flash	Not working			By
23.7.24	Pest o Flash	Not working			By
25.7.24	Pest o Flash	Not working			By
27.7.24	Pest o Flash	Not working			By
29.7.24	Pest o Flash	Not working			By
31.7.24	Pest o Flash	Not working			By
3.8.24	Pest o Flash	Not working			By
5.8.24	Pest o Flash	Not working			By
7.8.24	Pest o Flash	Not working			By
9.8.24	Pest o Flash	Not working			By
11.8.24	Pest o Flash	Not working			By
13.8.24	Pest o Flash	Not working			By
15.8.24	Pest o Flash	Not working			By
17.8.24	Pest o Flash	Not working			By
19.8.24	Pest o Flash	Not working			By
21.8.24	Pest o Flash	Not working			By
23.8.24	Pest o Flash	Not working			By
25.8.24	Pest o Flash	Not working			By
27.8.24	Pest o Flash	Not working			By
29.8.24	Pest o Flash	Not working			By
31.8.24	Pest o Flash	Not working			By
3.9.24	Pest o Flash	Not working			By
5.9.24	Pest o Flash	Not working			By
7.9.24	Pest o Flash	Not working			By
9.9.24	Pest o Flash	Not working			By
11.9.24	Pest o Flash	Not working			By
13.9.24	Pest o Flash	Not working			By
15.9.24	Pest o Flash	Not working			By
17.9.24	Pest o Flash	Not working			By
19.9.24	Pest o Flash	Not working			By
21.9.24	Pest o Flash	Not working			By
23.9.24	Pest o Flash	Not working			By
25.9.24	Pest o Flash	Not working			By
27.9.24	Pest o Flash	Not working			By
29.9.24	Pest o Flash	Not working			By
31.9.24	Pest o Flash	Not working			By
3.10.24	Pest o Flash	Not working			By
5.10.24	Pest o Flash	Not working			By
7.10.24	Pest o Flash	Not working			By
9.10.24	Pest o Flash	Not working			By
11.10.24	Pest o Flash	Not working			By
13.10.24	Pest o Flash	Not working			By
15.10.24	Pest o Flash	Not working			By
17.10.24	Pest o Flash	Not working			By
19.10.24	Pest o Flash	Not working			By
21.10.24	Pest o Flash	Not working			By
23.10.24	Pest o Flash	Not working			By
25.10.24	Pest o Flash	Not working			By
27.10.24	Pest o Flash	Not working			By
29.10.24	Pest o Flash	Not working			By
31.10.24	Pest o Flash	Not working			By
3.11.24	Pest o Flash	Not working			By
5.11.24	Pest o Flash	Not working			By
7.11.24	Pest o Flash	Not working			By
9.11.24	Pest o Flash	Not working			By
11.11.24	Pest o Flash	Not working			By
13.11.24	Pest o Flash	Not working			By
15.11.24	Pest o Flash	Not working			By
17.11.24	Pest o Flash	Not working			By
19.11.24	Pest o Flash	Not working			By
21.11.24	Pest o Flash	Not working			By
23.11.24	Pest o Flash	Not working			By
25.11.24	Pest o Flash	Not working			By
27.11.24	Pest o Flash	Not working			By
29.11.24	Pest o Flash	Not working			By
31.11.24	Pest o Flash	Not working			By
3.12.24	Pest o Flash	Not working			By
5.12.24	Pest o Flash	Not working			By
7.12.24	Pest o Flash	Not working			By
9.12.24	Pest o Flash	Not working			By
11.12.24	Pest o Flash	Not working			By
13.12.24	Pest o Flash	Not working			By
15.12.24	Pest o Flash	Not working			By
17.12.24	Pest o Flash	Not working			By
19.12.24	Pest o Flash	Not working			By
21.12.24	Pest o Flash	Not working			By
23.12.24	Pest o Flash	Not working			By
25.12.24	Pest o Flash	Not working			By
27.12.24	Pest o Flash	Not working			By
29.12.24	Pest o Flash	Not working			By
31.12.24	Pest o Flash	Not working			By

Director
C.S.I. College of Engineering
Kottai-643 275, The Nilgiris.

PRINCIPAL

U.S.I. COLLEGE OF ENGINEERING


KBTI - 643 216.





CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (F.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



PLUMBING MAINTANENCE REGISTER

R. Mury Shanmugam

PRINCIPAL

CSI COLLEGE OF ENGINEERING,
KETTI - 643 216.





CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f. 31 12 2001)



DATE	NAME OF THE STUDENT	YEAR	SEM	NATURE OF THE COMPLAINT	STUDENT SIGN	PLUMBER SIGN	WOMEN SIGN	REMARKS
05/11/24	S. Paul	2nd	10	changing Tap 5 No. 10		Work completed	fin	Work done
05/11/24	PRINCE	EEF	14	clean bed problem	AS-E			
18/11/24	R. D. Dhanalak	March	17	water basin is blocked and no water flows at 3rd wing	R. D. Dhanalak			
18/11/24	R. D. Dhanalak	March	17	No water flow at 2nd floor in 2nd wing	R. D. Dhanalak			
02/12/24	Shirany V	EEF	04	Restroom Maintenance (Not in proper state)	V. J.			
08/12/24	R. Manojan	CSF	52	Blocking the window glass	R. Manojan			



R. Manoj Shanthi

CSI COLLEGE OF ENGINEERING
KETTI-643 216,



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f. 31 12 2001)



DATE	NAME	Room No	REPORT	STATUS	WORK START	STAFF	REMARK
10/1/24			Boys hostel doors water detector checked electrical line good condition 10/1/24 found (cupboard) water pipe tap found closed Revisited.	Open	Ann. Mar. 2024		
11/1/24	Basu	61	Light	Open			
18/3/24	Therai	visiting	and water detector checked found good condition	Open			
27/3/24	Sanjay	52	Tube light not glowing problem	Open			
3/3/24	Karthik	05	water filter broke	Open			
31/3/24	Santhosh	63	switch box damaged	Open			
2/5/24	R.D. Vinod	47	Corridor light has been already hung one at the Corridor and one at the Tunnel	Open			
14/6/24	D. Anand		water detector (no water supply) working good condition.	Open			
10/7/24	Abhishek	26		Open			
10/8/24	Tharun	227	Light (the water)	Open			



R. Mary Shanthi

PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 216



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23.3.1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31.12.2001)



DATE	Dept	Staff Sign
12/8/24	Phy - Lab, Staff Room	PCS
12/8/24	Maths department Staff Room	A. S. S. S. S. S. 12/8/24
12.8.24	Communication Lab	S. S. S. S. S. 12/8/24
12.08.24	Chemistry Dept & Lab	S. S. S. S. S. 12/8/24
13.08.24	Communication Lab	S. S. S. S. S. 13/8/24
13/08/24	Chemistry Dept & Lab	S. S. S. S. S. 13/8/24
13/08/24	Maths Staff Room	R. S. S. S. S. 13/8/24
13/08/24	Phy - Lab & Staff Room	PCS
13/8/24	Project Lab	PCS
16/8.24	Communication Lab	S. S. S. S. S. 16/8/24
16/08/24.	Chemistry Dept	S. S. S. S. S. 16/08/24
16/08/24	Maths staff Room	R. S. S. S. S. 16/8/24
16/08/24	Phy - Lab & Staff Room	PCS
19.08.24	Communication Lab	S. S. S. S. S. 19/8/24
19.08.24	Chemistry Lab	S. S. S. S. S. 19/08/24
19/08/24	Maths staff Room	S. S. S. S. S. 19/8/24
19/08/24	Phy - Lab & Staff Room	PCS
20/02/24	Phy - Lab & Staff Room	PCS
20/08/24	Maths - Staff Room	(S. S. S. S. S.)
20.08.24	Chemistry Dept	S. S. S. S. S. 20/8/24

LABORATORY CLEANING MAINTANENCE RECORD



R. M. S. S. S.

PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 216.



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (F.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23.3.1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31.12.2001)



DATE	Department	Sign
28/10/24	Phy Lab & Staff Room	PCS
29/10/24	Phy Lab & Staff Room Class Room	PCS
29/10/24	Communication Lab and Corridor	Shankar
30/10/24	Mathematics Department & Verandah	PCS
5/11/24	Phy Lab & Staff Room Class Room (H)	PCS
5/11/24 & 7/11/24	Chemistry Lab & Staff room & Class Room	Shankar
7/11/24	Communication Lab & Verandah	Shankar
7/11/24	Class rooms first year	Shankar
7/11/24	Mathematics Dept	Shankar
8/11/24	Chemistry Lab & Staff Room	Shankar
8/11/24	Communication Lab & Verandah	Shankar



R. Mury Shantra

PRINCIPAL

CSI COLLEGE OF ENGINEERING

KETTI-643 218.



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (F.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



Telephone No.		E-mail ID	
Room Group		Birth Day	
Sr.No	Title	Page No.	Sign./Remarks
1	TRAC 12/8/24	cleaned	[Signature]
2	R. PRASAD / Mr. Bhu	cleaned	[Signature]
3	CAD/CAM LAB	cleaned	[Signature]
	MECHANICS LAB		
4	11C - 12.8.24	cleaned	[Signature]
	13/2/24		
1	Office work		
	14/8/24		
1	Cad Cam	cleaned	[Signature]
2	Deen Daan	[Signature]	
3	Mechanics Lab	[Signature]	
4	Library	Ref	[Signature]
5	HOD room	cleaned	[Signature]
	14/8/24		
1	CAD CAM	cleaned	[Signature]
2	Deen Room	cleaned	
	19/8/24		
1	11C - Ref	cleaned	[Signature]
2	CAD CAM LAB	cleaned	[Signature]
	16/8/24		
1	Office		[Signature]
2	Deen LAB		[Signature]
3	Exam cell / Victoria	19/8/24 cleaned	[Signature]



R. Mury Shanthi

PRINCIPAL

CSI COLLEGE OF ENGINEERING
KETTI - 643 216.



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (F.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



5/12/2024 - CAD/CAM - Lab - Mechanics - Lab - Lecture Hall 1, 2, 13 - Computer Station - Exam Cell 3/12/2024 - CAD/CAM Lab - Mechanics Lab - Lecture Hall 125 - Computer 11C - All - 6-12-24 Exam Cell - 6-12-24 POC Cell - 6-12-24 CAD Lab Class room Mechanics Lab	Library - 07/12/2024 I side - } cleared Out side - } cleared 7/12/24 Exam Lab mechanics Lab Lathe shop 4/12/24 Exam Cell - cleared - V 11C - cleared - V
--	--



R. Mury Shantri

PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 215



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (I)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide G.O Ms. No. 112, Dated 23.3.1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f. 12.2001)



CSI COLLEGE OF ENGINEERING, KETTI STOCK

Sl. No.	Date of Purchase	Particulars	Qty	Unit Price	Total
1	20/12/20	Three Bicycles	3	900/-	2700/-
2	20/12/20	Spinning wheel	1		
3	20/12/20	Spinning wheel	1		
4	20/12/20	Spinning wheel	1		
5	20/12/20	Spinning wheel	1		
6	20/12/20	Spinning wheel	1		
7	20/12/20	Spinning wheel	1		
8	20/12/20	Spinning wheel	1		
9	20/12/20	Spinning wheel	1		
10	20/12/20	Spinning wheel	1		
11	20/12/20	Spinning wheel	1		
12	20/12/20	Spinning wheel	1		
13	20/12/20	Spinning wheel	1		
14	20/12/20	Spinning wheel	1		
15	20/12/20	Spinning wheel	1		
16	20/12/20	Spinning wheel	1		
17	20/12/20	Spinning wheel	1		
18	20/12/20	Spinning wheel	1		
19	20/12/20	Spinning wheel	1		
20	20/12/20	Spinning wheel	1		

KETTI, THE NILGIRIS - 643 215 REGISTER

29

Sl. No.	Date of Purchase	Particulars	Qty	Unit Price	Total
1	20/12/20	Three Bicycles	3	900/-	2700/-
2	20/12/20	Spinning wheel	1		
3	20/12/20	Spinning wheel	1		
4	20/12/20	Spinning wheel	1		
5	20/12/20	Spinning wheel	1		
6	20/12/20	Spinning wheel	1		
7	20/12/20	Spinning wheel	1		
8	20/12/20	Spinning wheel	1		
9	20/12/20	Spinning wheel	1		
10	20/12/20	Spinning wheel	1		
11	20/12/20	Spinning wheel	1		
12	20/12/20	Spinning wheel	1		
13	20/12/20	Spinning wheel	1		
14	20/12/20	Spinning wheel	1		
15	20/12/20	Spinning wheel	1		
16	20/12/20	Spinning wheel	1		
17	20/12/20	Spinning wheel	1		
18	20/12/20	Spinning wheel	1		
19	20/12/20	Spinning wheel	1		
20	20/12/20	Spinning wheel	1		

TRANSPORT MAINTANENCE RECORD



R. Mary Shanthi

PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 215



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (E.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)

Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)

Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



CSI College of Engineering, Ketti

STOCK

No	Date of PO	DC No & Date	Particulars	QTY	Rate	Amount
1	2/1/20	2/1/20	Concrete Limestone	1	5000	
2	2/1/20	2/1/20	Concrete Limestone	1	15.10	
3	2/1/20	2/1/20	Concrete Limestone	1	850	
4	2/1/20	2/1/20	Concrete Limestone	1	360	
5	2/1/20	2/1/20	Concrete Limestone	1	1900	
6	2/1/20	2/1/20	Concrete Limestone	1	1800	
7	2/1/20	2/1/20	Concrete Limestone	200	9000	
8	2/1/20	2/1/20	Concrete Limestone	2000	2000	
9	2/1/20	2/1/20	Concrete Limestone	6000	6000	
10	2/1/20	2/1/20	Concrete Limestone	8000	8000	
11	2/1/20	2/1/20	Concrete Limestone	1	300	
12	2/1/20	2/1/20	Concrete Limestone	1	300	
13	2/1/20	2/1/20	Concrete Limestone	1	1000	
14	2/1/20	2/1/20	Concrete Limestone	100	100	
15	2/1/20	2/1/20	Concrete Limestone	500	500	
16	2/1/20	2/1/20	Concrete Limestone	300	300	
17	2/1/20	2/1/20	Concrete Limestone	50	50	
18	2/1/20	2/1/20	Concrete Limestone	1200	1200	
19	2/1/20	2/1/20	Concrete Limestone	300	300	
20	2/1/20	2/1/20	Concrete Limestone	2000	2000	

KETTI THE NILGIRIS - 643 215 REGISTER

133

Sl No	Date of PO	DC No & Date	Particulars	QTY	Rate	Amount
1	2/1/20	2/1/20	Concrete Limestone	1	4250/-	
2	2/1/20	2/1/20	Concrete Limestone	1	1100/-	
3	2/1/20	2/1/20	Concrete Limestone	10,000	10,000	
4	2/1/20	2/1/20	Concrete Limestone	9000	9000	
5	2/1/20	2/1/20	Concrete Limestone	8000	8000	
6	2/1/20	2/1/20	Concrete Limestone	300/-	300/-	
7	2/1/20	2/1/20	Concrete Limestone	300/-	300/-	
8	2/1/20	2/1/20	Concrete Limestone	1000/-	1000/-	
9	2/1/20	2/1/20	Concrete Limestone	2450/-	2450/-	
10	2/1/20	2/1/20	Concrete Limestone	2900/-	2900/-	



R. Mury Shantri

PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 215

PRINCIPAL
C.S.I. COLLEGE OF ENGINEERING
KETTI - 643 215



CSI COLLEGE OF ENGINEERING, KETTI

Approved by AICTE, New Delhi (F.No. 730-52-301 (E)ET (97 Dated NOV 17, 1997)
Government of Tamil Nadu (vide GO Ms. No. 112, Dated 23 3 1998)
Affiliated to Anna University, Chennai (Tamil Nadu Act 26 of 2001 w.e.f.31 12 2001)



CSI COLLEGE OF ENGINEERING STOCK

Sl. No.	Date of PO	QC No. & Date	Invoice No. & Date	Item with Specification	Qty	Unit Rate	Tax
97	15/10/97		85	Green-Brown Paint 4kg		500/-	
				Red Paint		200/-	
	19/10/97		123	Latex		130/-	
	19/10/97			Red-Brown Latex 4kg		130/-	
				PC-1000			
97	20/10/97		139	Engine oil - 20W/50		3500/-	
				Engine oil 10W/40		200/-	
				Engine oil 10W/30		1600/-	
				Engine oil 10W/20		120/-	
				Engine oil 10W/10		440/-	
				Engine oil 10W/5		160/-	
				Engine oil 10W/0		70/-	
				Engine oil 10W/0		30/-	
97			166	Black Paint		2200/-	
			175	Black Paint		1515/-	
			176	Black Paint		1820/-	
			200	Light & Dark		1530/-	
				Physical Science & Engg.		200/-	
				PC-1000		5200/-	
97				PC-1000		1200/-	
97			1306	Green Primer		1200/-	
				Green Primer			

KETTI, THE NILGIRIS - 643 215 REGISTER

134

Invoice No.	Net Amount	O/B	C/B	Suppliers Details	Payment Type	Page No. of Invoice	Page No. of Bill	Principal's Sign	Remarks
	500/-			Blanco					
	200/-			Agencia					
	130/-			Latex					
	130/-			Red-Brown					
				Agencia					
	2200/-			Black Paint					
	2200/-			Black Paint					
	1530/-			Light & Dark					
	1530/-			Physical Science & Engg.					
	5200/-			PC-1000					
	1200/-			PC-1000					
	1200/-			Green Primer					
				Green Primer					



R. Muey Shanmugam

PRINCIPAL
CSI COLLEGE OF ENGINEERING
KETTI - 643 215.

Electrical Maintenance/Service (Upto May 2024)

Si No	Date	Electrical Maintenance/Service
1	06-06-2023	Transformer Breather Silica gel changes
2	22-08-2023	Transformer Breather Silica gel changes
3	29-09-2023	Transformer Breather Silica gel changes
4	11-10-2023	MPMC LAB tube lights has been serviced
5	13-10-2023	Bus Garrage Power Supply Switch Bars and Flood lights fixed
6	24-11-2023	Siren Repaired -By replacing carbon brushes
7	05-12-2023	Transformer Breather Silica gel changes
8	09-12-2023	Main Gate Focuss Lights Fixed-20 Watts 2 Nos
9	01-09-2024	Oil Service had been carried out for College Generator.
10	16-01-2024	Director room LED changed
11	13-02-2024	Battery Interchanged from S & H to Accounts Office
12	13-03-2024	Transformer Breather Silica gel changes
13	14-02-2024	Hostel Pumpset starters Repaired.
14	10-04-2024	Server Batter Shifted from Mechanical Block
15	10-04-2024	Water Purifier has been serviced
16	19-04-2024	College pumpset battery has been replaced
17	07-05-2024	Water Purifier has been serviced
18	17-05-2024	Account Section LED lights rearranged
19	17-05-2024	Smart TV wiring
20	24-05-2024	College Main gate intercom line shifed to Security Office
21	31-05-2024	Admission Office switch wiring. EEE block 2KVA UPS shifted fromaccounts



R. Mary Shanthi

PRINCIPAL
U.S.I. COLLEGE OF ENGINEERING
KETTI-643 216.